T.V. Ferguson, A. Guinzburg, R.D. McGlynn and M. Williams The Boeing Co.

Rocketdyne Propulsion & Power Canoga Park CA 91309

JANNAF Meeting Destin Florida April 2002 BOEING

Motivation and objectives

Test article

Test facility and setup

Test procedures

Test data results and discussion

Summary and conclusions

NRA history

- · Work funded as part of NRA8-21 cycle 2 RBCC Turbopump Risk Reduction
- Input submitted April 1999 → task funded May 2001
- \$1.3M contract, planned term: 19.5 months
- Expenditures: \$440K; contract cancelled 1/02: lack of funds

Objectives

- Enhance and demonstrate critical technologies in support of planned RBCC flight test program
- rocket engine turbopumps operating over extreme throttle ranges Obtain knowledge of wide flow range as it is applicable to liquid

NASA partner acknowledgments

Mr. Robert Garcia and Dr. Dan Dorney of MSFC

Rocketdyne Propulsion & Power

BOEING

3

Wide Flow Range (WFR) Scope of Work

· Improve TP performance at off-design flows by designing and testing diffusers suitable for WFR operation

Program divided into 4 major activities

this talk

· Task 1: Diffuser flow test and database analysis

Collect vane-island diffuser data at off-design Q

· Database analysis incomplete (not funded)

prior

Task 2: Candidate WFR diffusers design & evaluation

Design, fabricate and test 2 WFR diffuser concepts

Design #1 complete, design #2 90% complete


Fabrication and testing incomplete (not funded)

· Task 3: Design, fabricate and test WFR TP stage (not funded) · Inducer, impeller and diffuser matched for WFR operation Task 4: RBCC top-level turbopump conceptual layout (not funded)

Rocketoyne Corporate knowledge gained to specific requirements Propulsion & Power

BOEING

4




0.574 249.505

47.0

6322 1210

Turbonump Technology Testing



14.703

4.886 6.757 0.403 0.601 0.466

9.355


Plastic models shown

Impeller shroud removed


BOEING


9












 $\boldsymbol{\sigma}$






PAGE: 09

10:256 544 1630

AUG-16 93 17:18 FROM:

Ø BOEING






Rocketdyne Propulsion & Power

PAGE: 10

10:526 544 1630


AUG-16 93 17:19 FROM:



PAGE: 11

10:526 544 1630

Ø BDEING



Rocketdyne Propulsion & Power

PAGE: 12


10:526 544 1630

AUG-16 93 17:21 FROM:

50% location 3 33% beation 17% Pocation 6 7 6 83% localion 67% location : 6 7 3 Impeller timing mark on shroud 053 location 100% location - Impelier RPM hrottle Turbopump Technology' - Suction side of bis de 60 deg decharge blade myck for blade fert Pressure side of blads --= 61 - Suction side of blade Neede angle for blade N 60 deg, charfter Importer Timing Man Service Pressure side of blatte 2

PAGE: 13


0531 pps 383:01



Rockeldyne Propulsion & Power

14

O BOEING



BOEIN

5

Rocketdyne Propulsion & Power

PAGE: 15

0591 PPS 925:0T

AUG-16 93 17:23 FROM:

 Laser velocimeter data collected over 2 days at impeller discharge across B2

51 total laser data files

4 flow rates: 100%, 80%, 30%, 120% Qd (Qd = 1210 gpm)

100% first: verify same flow as 1996

80% second: contract objective

30% third: anchor CFD at low Qd

120% fourth: anchor CFD at high Qd

• 11 points across B2: 0, 10, 20, ... 90, 100% (B2 = 0.58")


Laser data collected was ensemble averaged (~ Kiel probe)

 Facility & pump overall performance data collection (monitoring files) active during laser data collection (~ 3 min)

Post-processing helped reveal timing of tester damage

BOEING

16



71:30A9

0531 PAR 363:0T


AUG-16 93 17:23 FROM:

Deep Throttle Turbopump Technology Testing


 Key factors that may explain differences between 2001 and 1996 data

- · Same impeller design, different unit
- 2001 impeller fabricated by same vendor using existing **CNC** tape
- 2001 impeller B2 0.010" wider than 1996 impeller
- Greater leakage flow through impeller laby seal
- Laby seal was more worn than in 1996 (new)
- Subtle differences in alignment procedures could lead to different angle correction factors

Deep Throttle Turbopump Technology Testing Control of the second




Deep Throttle Turbopump Technology Testing



MAR 27 '02 13:02

PAGE.20

Time History of Representative Parameters



MAR 27 '02 13:02


PAGE.21


& BOEING




Rocketdyne Propulsion & Power

MAR 27 '02 13:03







MAR 27 '02 13:04


PAGE.24

Deep Throttle Turbopump Technology Testing

- First data sets
- 100% Qd data from 2001 reasonably close to 1996 data
- 80% Qd data from 2001 probably OK up to certain point
- Data at 0, 10, 20, 30, 40, 50, 60, 70% B2 OK
- Data at 80, 90, 100% B2 occurred after diffuser piece broke
- Damage was not detected at this point and testing continued
- Data rate problems encountered at 30% Qd
- Solution: inject metal coated glass microspheres into fluid to boost data rate (higher SNR)
- GN2 used to inject seeds leaked into water
- Monitoring files showed this caused loss of impeller head with probable impact on discharge flow field

Rocketdyne Propulsion & Power


BUEING



MAR 27 '02 13:05

PAGE.26

Time History of Representative Parameters



MAR 27 '02 13:05

Deep Throttle Turbopump Technology Testing

Four flowrate summary

- · 100% Qd data
- 80% Qd data
- Data at 0, 10, 20, 30, 40, 50, 60, 70% B2

status -


Hardware status

- Data at 80, 90, 100% B2
- 30% Qd data
- Data at 0, 10, 20, 50% B2: before GN2 injection
- Data at 30 & 40% B2: GN2 in water
- Data at 60, 70, 80, 90, 100% B2: after GN2 escape
- 120% Od data
- Data at 0, 10, 20, ... 90, 100% B2

(BOEING

 Area-averaged flowrate calculation using laser data yields integrated flowrate: compare to actual flowmeters

 Assume impeller exit flow measured at one location with respect to a particular diffuser vane is same for all diffuser vanes Tester had single window located at fixed location relative to a specific pair of diffuser vanes



(BOEING


Deep Throttle Turbopump Technology Testing

Calculation methodolgy

- Use Excel to determine polynomial curve fit to 11 points of Cr data across impeller B2 at each of 4 flowrates
- Using curve fit equation, set up SS to calculate velocity at 100 points across B2 (interpolated)
- Calculate average velocity data from n and n+1 points
- Assign that average velocity to cell bordered by n and n+1 points
- Calculate flow rate in that cell based on averaged velocity
- Sum all averaged velocity-based flowrates in all 100 cells to get total flow rate

Deep Throttle Turbopump Technology Test





ttle Turbopump Technology Testing

% B2 distance ring area (%) (in) (in^2) (in^2) 0 0.000000 0.168810 1 0.005840 0.168810 3 0.017520 0.168810 4 0.023360 0.168810 5 0.029200 0.168810 6 0.035040 0.168810		100% Qd calculations	ons	
(in) 0.000000 0.005840 0.011680 0.017520 0.023360 0.029200 0.035040		calculated radial velocity		Q calc.
0.005840 0.011680 0.017520 0.023360 0.029200 0.035040	(ft/s)	avg (ft/s) (ii	(in/s)	(mdb)
0.005840 0.011680 0.017520 0.023360 0.029200	17.482271			
0.005840 0.011680 0.023360 0.029200 0.035040	人 —	18.603988 223.2	223.247855	9.672721
0.011680 0.017520 0.023360 0.029200	19.725704			
0.011680 0.017520 0.023360 0.029200		20.707972 248.4	248.495666	10.766640
0.023360 0.029200 0.035040	21.690240			
0.023360 0.029200 0.035040		22.544395 270.5	270.532738	11.721447
0.023360	23.398550			
0.023360		24.135316 289.6	289.623796	12.548610
0.029200	110 24.872083			
0.029200		25.501593 306.0	306.019117	13.258975
0.035040	.10 26.131103		•	
0.035040		26.662916 319.9	319.954995	13.862778
	10 27.194729			
		27.637849 331.6	331.654193	14.369673
7 0.040880 0.168810	10 28.080970		:	

BOEING

Flow as % of Qd (%) 120 100	Target flowrate (gpm) 1452 1210	Avg. measured flowrate flowrate (gpm) Integrated calculated flowrate (gpm) (% of attained) 1451.9 1428.8 98.4 1214.9 1106.8 91.1 969.6 364.1 37.6	(gpm) 1428.8 1106.8 364.1	culated flowrate (% of attained) 98.4 91.1
	() ()	נט נט ניט	504.9	77

BOEING


Deep Throttle Turbopump Technology Testing

Interpretations of results

- Close continuity match (91%) at 100%Qd suggests data is approximately correct
- · Similarity between 1996 data and 2001 data supports this assertion
- damage to diffuser and impeller may not have significantly altered flow field, components working about as designed Close continuity match (98%) at 120% Qd could suggest
- Therefore, continuity mis-match at 80% and 30% Qd might be evidence of real flow phenomena
- Stall mechanism at work?
- Mass inbalance through diffuser vanes?

(BOEING

- Interpretations of results
- 1996 pressure data at impeller discharge shows pressure fluctuations at 60% Qd
- CFD calculations show vane-to-vane mass flow inbalance at
- More data analysis with tie-in to pressure data needed



Deep Throttle Turbopump Technology Testing The second of the second of the second

- Program was setup to demonstrate wide flow range diffuser **technologies**
- Testing phase of contract to provide data to anchor initial designs partially successful
- Data collected suggest flow phenomena exists at off-design flowrates
- Cause and mechanism not well understood
- Data analysis not complete before end of funding
- Data can be better understood with more analysis and comparison to pressure measurements

